

Test Pits – NH-1184 – Nottingham, NH – Langdon – 6/1/2020
Conducted by Christian O. Smith, P.E. - Beals Associates, PLLC - #1543

Test Pit # 17

0" – 10"	10YR 3/4	Dark Yellowish Brown Fine Sandy Loam Granular, Friable
10" - 21"	10YR 5/6	Yellowish Brown Fine Sandy Loam Blocky, Friable
21" – 28"	2.5Y 5/4	Light Olive Brown Fine Sandy Loam Platy, Friable
28" – 58"	2.5Y 5/3	Light Olive Brown Silt Loam Platy, Firm w/ Redox
58" – 72"	2.5Y 6/3	Light Yellowish Brown Medium Sand Massive, Very Friable, w/ Redox

ESHWT = 28 Inches
Roots to 25 Inches
Observed Ground Water – None
Restrictive – 28 Inches
Refusal – None
Perc Rate 6 min/Inch

