



Nottingham Fire - Rescue Department
235 Stage Road
PO Box 114
Nottingham, NH 03290-0114

Business (603) 679-5666
Facsimile (603) 679-1271

Ser # 2021-090

25 May 2021

Emergency Dial 9 1 1

Jaye J. Vilchock
Chief

JoAnna Arendarczyk
 Town of Nottingham NH Planning Board, Land Use Clerk
 PO Box 114
 Nottingham, NH 03290

SUBJECT: Plan Review for Fire Protection; Subdivision Plan for Robert L. Diberto (Tax MAP 7, LOT 1N) Mitchell Rd. Nottingham, New Hampshire; Dated March 16, 2020, prepared by Berry Surveying & Engineering. Case #20-003-SUB


IAW your 24 May 2021 verbal request, an updated fire protection review of subject plan by Nottingham Fire Rescue Department (NFRD) was completed.

- (1.) **All cisterns shall be installed in accordance with Town of Nottingham Subdivision Regulations, Appendix 5, "FIRE CISTERN SPECIFICATIONS".** Agree with a 30,000-gallon cistern in location depicted on sheet 13 of 55.
- (2.) As always NFRD, recommend fire protection of all residences be provided by sprinkler systems that at a minimum meet the requirements of NFPA 13-D, **"Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes."**

If any additional information is needed, please contact the undersigned at Nottingham Fire Rescue Headquarters via 679.5666 during normal business hours.

Sincerely,

Jaye Vilchock 25 MAY 2021
 Jaye Joseph Vilchock
 Chief, Nottingham
 Fire Rescue



cc: File
 Building Inspector
 TA