



Nottingham Fire - Rescue Department
235 Stage Road
PO Box 114
Nottingham, NH 03290-0114

Business (603) 679-5666
Facsimile (603) 679-1271

Ser # 2020-092

31 May 2020 **Emergency Dial 9 1 1**

JoAnna Arendarczyk
Town of Nottingham NH Planning Board, Land Use Clerk
PO Box 114
Nottingham, NH 03290

SUBJECT: Plan Review for Fire Protection; Subdivision Plan for Robert L. Diberto (Tax MAP 7, LOT 1N) Mitchell Rd. Nottingham, New Hampshire; Dated March 16, 2020, prepared by Berry Surveying & Engineering. Case #20-003-SUB

Jaye J. Vilchock
Chief

Matthew R. Curry
Deputy Chief

Mark Pedersen
Heidi Carlson
Captains

Sandra J. Vilchock
Steven Ross
Grace W. Russell
Joshua Boyle
Lieutenants

As requested by your 27 May 2020 memo, a fire protection review of subject plan by Nottingham Fire Rescue Department (NFRD) was completed.

- (1.) All cisterns shall be installed in accordance with Town of Nottingham Subdivision Regulations, Appendix 5, "FIRE CISTERN SPECIFICATIONS".
- (2.) As always NFRD, recommend fire protection of all residences be provided by sprinkler systems that at a minimum meet the requirements of NFPA 13-D, "**Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes.**"

If any additional information is needed, please contact the undersigned at Nottingham Fire Rescue Headquarters via 679.5666 during normal business hours.

Sincerely,


Jaye Joseph Vilchock
Chief, Nottingham
Fire Rescue

cc: File
Building Inspector
TA