



Nottingham Fire - Rescue Department
235 Stage Road
PO Box 114
Nottingham, NH 03290-0114

Business (603) 679-5666
Facsimile (603) 679-1271

Ser # 2021-022

20 February 2021 **Emergency Dial 9 1 1**

Jaye J. Vilchock
Chief

Matthew R. Curry
Deputy Chief

JoAnna Arendarczyk
 Town of Nottingham NH Planning Board, Land Use Clerk
 PO Box 114
 Nottingham, NH 03290


SUBJECT: Review for Fire Protection; Subdivision Plan for Land of Diane Monti (Tax MAP 40, LOT 1) Gile Rd., Nottingham, New Hampshire; Dated December 30, 2020. **Case #21-002-SUB.**

As requested by your 17 February 2021 memo, a fire protection review of subject plan was completed by Nottingham Fire Rescue Department (NFRD). The following comments are provided for adjudication:

- (1.) NFRD recommends a 30,000-gallon cistern (installed IAW **Town of Nottingham Subdivision Regulations, Appendix 5, "FIRE CISTERN SPECIFICATIONS"**) be located at the Gile Road boundary of lot # 5. Exact location is subject to review and approval of Fire Chief. Cistern shall be installed, tested and approved by Fire Chief prior to issuing any occupancy permits for this subdivision.
- (2.) In lieu of installation of cistern, NFRD recommend fire protection of all residences be provided by sprinkler systems that at a minimum meet the requirements of NFPA 13-D, **"Standard for the Installation of Sprinkler Systems in One-and Two-Family Dwellings and Manufactured Homes."**

If any additional information is needed, please contact the undersigned at Nottingham Fire Rescue Headquarters via 679.5666 during normal business hours.

Sincerely,

 20 FEBRUARY 2021
 Jaye Joseph Vilchock
 Chief, Nottingham
 Fire Rescue

cc: File
 Building Inspector
 TA

