



Nottingham Fire - Rescue Department
235 Stage Road
PO Box 114
Nottingham, NH 03290-0114

Business (603) 679-5666
Facsimile (603) 679-1271

Ser # 2021-023

20 February 2021 **Emergency Dial 9 1 1**

Jaye J. Vilchock
Chief

Matthew R. Curry
Deputy Chief

JoAnna Arendarczyk
 Town of Nottingham NH Planning Board, Land Use Clerk
 PO Box 114
 Nottingham, NH 03290

SUBJECT: Review for Fire Protection; Site Plan for KUBOTA TRUST
 (Tax MAP 69, LOT 10) 214 Raymond Rd., Nottingham, New
 Hampshire; Dated January 20, 2021. **Case #21-003-SIT.**

As requested by your 8 February 2021 memo, a fire protection review of
 subject plan was completed by Nottingham Fire Rescue Department
 (NFRD). The following comments are provided for adjudication:

- (1.) Maximum capacity of spectators, vendors, parking, campers need to be provided.
- (2.) Detail of vendor areas needs to be provided to ensure compliance with applicable safety codes.
- (3.) Detail of parking area, pit area, camping area and overflow areas need to be provided to ensure adequate access/egress for emergency services.
- (4.) Descriptions of temporary structures (vendors etc.) needs to be provided to ensure compliance with safety codes.
- (5.) Total number of rest room facilities needs to be scaled to maximum allowed attendance.
- (6.) No fires are permitted.
- (7.) Dedicated EMS services must be on site during event.
- (8.) Spectator seating capacity and style needs to be identified.
- (9.) All food vendors, temporary structures shall comply with applicable provisions of NFPA (1) and NFPA (96). Authority Having Jurisdiction (AHJ) reserves final decision authority in these matters.
- (10.) Access to all neighboring residences shall not be impeded, nor blocked.

If any additional information is needed, please contact the undersigned at Nottingham Fire Rescue Headquarters via 679.5666 during normal business hours.

Sincerely,

Jaye J. Vilchock 20 FEB 2021
 Jaye Joseph Vilchock
 Chief, Nottingham
 Fire Rescue

cc: File
 Building Inspector
 TA

