

Test Pits – NH-1184 – Nottingham, NH – Langdon – 6/8/2020
Conducted by Christian O. Smith, P.E. - Beals Associates, PLLC - #1543

Test Pit # 18

0" – 12"	10YR 3/4	Dark Yellowish Brown Fine Sandy Loam Granular, Friable
12" - 29"	10YR 4/6	Dark Yellowish Brown Fine Sandy Loam Blocky, Friable
29" – 68"	2.5Y 5/4	Light Olive Brown Fine Sand Massive, Friable w/ Redox

ESHWT = 29 Inches

Roots to 25 Inches

Observed Ground Water – 52" (weeping from pit walls)

Restrictive – None

Refusal – None

Perc Rate 6 min/Inch

