



**Nottingham Fire - Rescue Department**  
**235 Stage Road**  
**PO Box 114**  
**Nottingham, NH 03290-0114**

**Business (603) 679-5666**  
**Facsimile (603) 679-1271**

Ser # 2022-140

**Emergency Dial 9 1 1**

**Jaye J. Vilchock**  
**Chief**

**Matthew R. Curry**  
**Deputy Chief**

**Mark Pedersen**  
**Captain**

**Sandra J. Vilchock**  
**Steven Ross**  
**Lieutenants**

10 August 2022

Kevin Lemieux  
 Town of Nottingham NH Planning Board, Land Use Clerk  
 PO Box 114  
 Nottingham, NH 03290

SUBJECT: Plan Review for Case #22-011-SUB Mooers Road

As requested by your 1543L, 2 August 2022 email, an initial fire protection review of subject plan by Nottingham Fire Rescue Department (NFRD)/Authority Having Jurisdiction (AHJ) was completed.

- (1.) Applicant submitted "Project Application Checklist" shows Fire Protection details as "N/A".
- (2.) Due to lack of year round fire protection water supply sites, i.e. cisterns or dry hydrants in the area, access conditions of Jampsa Trail and number of proposed single family residences AHJ (requires a 30,000 gallon cistern on Jampsa Trail and a 30,000 gallon cistern on Mooers Road.
- (3.) Cistern construction and installation methods shall be in accordance with Town of Nottingham Subdivision Regulations, Appendix 5, "FIRE CISTERN SPECIFICATIONS".
- (4.) Cistern installation inspection, installation approval and acceptance shall be made by AHJ.
- (5.) Applicant is responsible for initial filling of all cisterns. Cisterns shall be filled to maximum design capacity prior to any AHJ leakage, pump testing.
- (6.) AHJ cistern acceptance shall be required prior to any residential occupancy.
- (7.) Additionally, AHJ recommends fire protection of all residences be provided by sprinkler systems that at a minimum meet the requirements of NFPA 13-D, "Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes."

If any additional information is needed, please contact the undersigned at Nottingham Fire Rescue Headquarters via 679.5666 during normal business hours.

Sincerely,

  
 Jaye Joseph Vilchock  
 Chief, Nottingham  
 Fire Rescue

cc: File  
 Building Inspector  
 TA